



DEEP SANITARY SEWER SERVICE: MAIN TO CLEANOUT

MAINLINE > 10' DEEP

N.T.S.

- NOTES:**
1. ALL CONNECTIONS SHALL BE GASKETED TYPE. NO GLUED CONNECTIONS OR FLEXIBLE COUPLING SHALL BE USED.
 2. CONNECTIONS TO EXISTING SEWERS SHALL BE PVC GASKETED TYPE WYE CONNECTION SADDLES.
 3. FURNO COUPLINGS WILL NOT BE ALLOWED.
 4. REFER TO MATERIAL LIST, S-03.
 5. LONG SIDE LATERALS: CONTRACTOR TO INSTALL WYE ON STANPIPE AND EXTEND LATERAL TO CLEANOUT AT RIGHT-OF-WAY; SHORT SIDE LATERALS: CONTRACTOR TO INSTALL STANDPIPE AND PRIVATE CONTRACTOR TO CUT IN WYE AND INSTALL LATERAL PIPE TO STRUCTURE.

ISSUE DATE: MAY 2015	
REVISIONS	
DATE	COMMENTS
06/2015	DEPTH CLARIFICATION

TOWN OF BATAVIA
SANITARY SEWER DETAILS
DEEP SANITARY SEWER SERVICE: MAIN TO CLEANOUT
DRAWING S-04B