



WATER SERVICE DETAIL: MAIN TO PIT

N.T.S.

NOTES:

- 1) STAINLESS STEEL INSERTS SHALL BE USED AT ALL HDPE CONNECTIONS.
- 2) PLUG END OF SERVICE LINE AT 5' HDPE EXTENSION IF NOT CONNECTED AT TIME OF METER PIT INSTALLATION.
- 3) HDPE SERVICE LINE SHALL BE ENCLOSED WITH A SLEEVE PIPE COVER PER WATER DEPT. OR 6" FINE SAND BEDDING ABOVE AND BELOW SERVICE AS APPROVED BY WATER DEPARTMENT.
- 4) HOUSE PENETRATION MUST HAVE SLEEVE 2X SERVICE SIZE SCHEDULE 40 PVC MIN. OR AS APPROVED.
- 5) TRACER WIRE SHALL BE PLACED ALONG ENTIRE HDPE SERVICE LINE AND BE ACCESSIBLE IN THE METER PIT.
- 6) A LARGER DIAMETER SERVICE LINE MAY BE REQUIRED WHERE DISTANCE, MAIN PRESSURE OR CONSUMER DEMAND ARE A FACTOR. IN SUCH CASES, CONTACT THE TOWN OF BATAVIA.
- 7) REFER TO MATERIAL LIST, W-03.

ISSUE DATE: JUNE 2015

| REVISIONS | DATE | COMMENTS |
|-----------|------|----------|
| | | |
| | | |
| | | |
| | | |

TOWN OF BATAVIA
 WATER DETAILS
**WATER SERVICE DETAIL:
 MAIN TO PIT**
 DRAWING W-04B