



NOTES:

- 1) STAINLESS STEEL SERVICE SADDLES SHALL BE USED ON ALL TAPS, SMITH BLAIR.
- 2) STAINLESS STEEL INSERTS SHALL BE USED AT ALL PE CONNECTIONS.
- 3) REFER TO MATERIAL LIST, W-03.

1" MANUAL AIR RELEASE & PERMANENT DISINFECTION TESTING TAP

N.T.S.

ISSUE DATE: JUNE 2015		TOWN OF BATAVIA
		WATER DETAILS
REVISIONS	DATE	COMMENTS
		1" MANUAL AIR RELEASE & DISINFECTION TAP
		DRAWING W-05