



NOTES:

- 1) THE VALVE BOX SHALL BE BACKFILLED SO THAT IT DOES NOT REST ON THE VALVE HOUSING.
- 2) ALL BOLTS AND NUTS SHALL BE FLUOROCARBON COATED (BLUE).
- 3) VALVE SHALL BE WRAPPED WITH 6 MIL. THICK POLYETHYLENE 2' BEYOND END OF VALVE.
- 4) REFER TO MATERIAL LIST, W-03.

GATE VALVE DETAIL

N.T.S.

ISSUE DATE: JUNE 2015		TOWN OF BATAVIA
		WATER DETAILS
REVISIONS	DATE	COMMENTS
		GATE VALVE DETAIL
		DRAWING W-10