



**PUBLIC SANITARY
YARD HYDRANT DETAIL**
N.T.S.

NOTES:

- 1) STAINLESS STEEL INSERTS SHALL BE USED AT ALL HDPE CONNECTIONS.
- 2) TAPE SERVICE LINE AT 5' HDPE EXTENSION IF NOT CONNECTED AT TIME OF METER PIT INSTALLATION.
- 3) HDPE SERVICE LINE SHALL BE ENCLOSED WITH A SLEEVE PIPE COVER OR FINE SAND BEDDING AS APPROVED BY THE WATER DEPT.
- 4) TRACER WIRE SHALL BE PLACED ALONG ENTIRE HDPE SERVICE LINE AND BE ACCESSIBLE IN THE METER PIT.
- 5) ALL COMMERCIAL/INDUSTRIAL YARD HYDRANTS SHALL INCLUDE INTEGRAL BACKFLOW PREVENTION.
- 6) REFER TO MATERIAL LIST, W-03.

ISSUE DATE: JUNE 2015		TOWN OF BATAVIA
		WATER DETAILS
REVISIONS	DATE	COMMENTS
		PUBLIC SANITARY YARD HYDRANT DETAIL
		DRAWING W-21