



SHALLOW SANITARY SEWER SERVICE: MAIN TO CLEANOUT

MAINLINE ≤ 10' DEEP
N.T.S.

NOTES:

1. ALL CONNECTIONS SHALL BE GASKETED TYPE. NO GLUED CONNECTIONS OR FLEXIBLE COUPLING SHALL BE USED.
2. CONNECTIONS TO EXISTING SEWERS SHALL BE PVC GASKETED TYPE WYE CONNECTION SADDLES.
3. FURNCO COUPLINGS WILL NOT BE ALLOWED.
4. REFER TO MATERIAL LIST, S-03.

ISSUE DATE: MAY 2015

TOWN OF BATAVIA

| REVISIONS | DATE | COMMENTS |
|-----------|---------|---------------------|
| | 06/2015 | DEPTH CLARIFICATION |
| | | |
| | | |
| | | |

SANITARY SEWER DETAILS

SHALLOW SANITARY SEWER SERVICE: MAIN TO CLEANOUT

DRAWING S-04A