



NOTES:

- 1) STAINLESS STEEL INSERTS SHALL BE USED AT ALL PE CONNECTIONS.
- 2) DIP FITTINGS SHALL BE WRAPPED WITH 6 MIL. THICK POLYETHYLENE, 2 FEET BEYOND THE END OF THE FITTING ON THE PVC PIPE.
- 3) ALL BOLTS AND NUTS SHALL BE FLUOROCARBON COATED.
- 4) REFER TO MATERIAL LIST, W-03.

2" BLOW-OFF AND THRUST BLOCK DETAIL

N.T.S.

ISSUE DATE: JUNE 2015

TOWN OF BATAVIA

WATER DETAILS

2" BLOW-OFF AND THRUST BLOCK DETAIL

DRAWING W-07

REVISIONS

DATE	COMMENTS
07/2017	REVERSE CAMLOCK FEMALE/MALE; COVER & FRAME
04/2018	REPLACED CORP WITH COUPLING