

REVISIONS			
DATE	COMMENTS		
06/2017	FIRE DEPARTMENT CONNECTION ADDED		
04/2018	UPDATED MODEL NUMBERS & CLARIFIED		
09/2018	UPDATED MODEL NUMBERS & REARRANGED		

ISSUE DATE: JUNE 2015

STANDARD MATERIAL LIST			
DESCRIPTION & DETAILS REFERENCED	ALTERNATIVE 1 MAKE/MODEL/MATERIAL	ALTERNATE 2 MAKE/MODEL/MATERIAL	COMMENTS
2" PERMANENT BLOW-OFF ASSEMBLY; W-07	SEE 2" WATER SERVICE - CURB BOX BELOW		
	SEE 2" WATER SERVICE - CURB STOP ON BELOW		
	2" QUICK JOINT COUPLING FORD C-84-77-Q	MUELLER 110 COUPLING, H-15428N	
	SEE WATER SERVICE - GRADE RING ON W-03C		
	EAST JORDAN 1566Z FRAME AND 1566 COVER	NEENAH R-1975-A2 FRAME AND COVER	
2" WATER SERVICE - SERVICE SADDLE; W-18	FORD FS313-XXX-CC S/S SERVICE SADDLE	SMITH BLAIR 372 S/S SERVICE SADDLE	
2" WATER SERVICE - CURB STOP; W-18	2" MUELLER 300 CURB VALVE B25209N	NO EQUAL - TOWN STANDARD	
2" WATER SERVICE - METER; W-18	2" SENSUS OMNI T2 WATER METER	NO EQUAL - TOWN STANDARD	TOWN STANDARD IS SENSUS METERS
2" WATER SERVICE; W-18	36" SQUARE EAST JORDAN CASTING ALUMINUM HATCH - H-20 UNINTENDED VEHICULAR TRAFFIC RATE H363610801	36" SQUARE BILCO J-AL-H20 ALUMINUM HATCH	FOR TOB OF 4' SQUARE PRECAST METER VAULT
GATE VALVE; W-07, W-10, W-13, W-20	RESILIENT SEAT, OPEN LEFT, NRS MUELLER MODEL A-2360 MJxMJ WITH S/S FASTENERS	RESILIENT SEAT GATE VALVE NRS, OPEN LEFT KENNEDY 8571 WITH S/S FASTENERS	
WATER MAIN - TAPPING SLEEVE; W-08, W-20	FORD MODEL FTSS STAINLESS STEEL TAPPING SLEEVE	SMITH BLAIR MODEL 665 STAINLESS STEEL TAPPING SLEEVE	
MECHANICAL JOINT PIPE RESTRAINT; W-08, W-09, W-10, W-11, W-12, W-14A	ROMAC XXX-GRAP-IP GRIP RING PIPE RESTRAINT	FORD UFR1500-x-U	
HYDRANT - MUNICIPAL; W-11	5-1/4 BREAK AWAY KENNEDY NO K81A - MUNICIPAL, PAINTED YELLOW	NO EQUAL - TOWN STANDARD	FIELD APPLY SECOND COAT OF YELLOW PAINT AFTER INSTALL. WIRE BRUSH LOOSE OR CHIPPED PAINT
HYDRANT - PRIVATE	5-1/4 BREAK AWAY KENNEDY NO K81D - MUNICIPAL, PAINTED RED		
IN LINE / HYDRANT VALVE BOX; W-10, W-11, W-13	TYLER UNION 6855 SLIP TYPE VALVE BOX	BINGHAM AND TAYLOR FIGURE 4908 SLIP TYPE VALVE BOX	ALTERNATIVE 3: BIBBY STE-CROIX TWO PIECE STYLE TOP FLANGE CODE V683; OR EQUAL
HYDRANT VALVE; W-11	6" RESILIENT SEAT, OPEN LEFT, NRS MUELLER MODEL A-2360 MJxMJ WITH S/S FASTENERS	6" RESILIENT SEAT GATE VALVE NRS, OPEN LEFT KENNEDY 8571 WITH S/S FASTENERS	
SANITARY YARD HYDRANT; W-21	FREEZE FLOW, EXECUTIVE SANITARY YARD HYDRANT, MODEL S135E		

TOWN OF BATAVIA  
WATER DETAILS

STANDARD  
MATERIAL LIST

DRAWING W-03B